



Certificate of Compliance

This certificate is issued for the following:

Polyethylene Pipe for Underground Fire Protection Service

Product Designation	O.D., Pipe Size, in.	Pressure Rating, psi (kPa)	Remarks
Class 200, SDR11 Pipe	2, 3, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24, 26, 28, 30, 32, 34, 36	200 (1380)	a, b, c
Class 250, SDR9 Pipe	2, 3, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24, 26, 28, 30, 32, 34, 36	250 (1725)	a, b, c
Class 335, SDR7 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	335 (2310)	a, b, c

Remarks:

- a. *Pipe and fittings may be directly connected together by the butt fusion process. Manufacturer's fusion instructions must be strictly followed for a proper fusion joint.*
- b. *The diameter basis is IPS & DPS sizes.*
- c. *Ideal Blue pipe Approved*

Prepared for:

WL Plastics Corp
3575 Lone Star Circle, Suite 300
Fort Worth, Texas 76177

FM Approval Standard Class 1613 (February 2017)

Approval Identification: PR450320 Approval Granted: February 18, 2019

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in black ink that reads 'David B. Fuller'.

David B. Fuller
VP, Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA