



Certificate of Compliance

This certificate is issued for the following:

Polyethylene (PE) Pipe and Fittings for Underground Fire Protection Service

(see attached listing)

Prepared for:

WL Plastics Corp
3575 Lone Star Circle Suite 400,
Ft. Worth, Texas 76177, USA

Approval Standard: FM 1613 (February 2017)

Approval Identification: PR457058
Revision Request: RR236302

Approval Granted: 7 August 2020
Date Authorized: 21 April 2023

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller", is written over a horizontal line.

David B Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group





Certificate of Compliance

| Product Description | Nominal Pipe Size, in | Rated Working Pressure | | Remarks |
|----------------------|--|------------------------|--------|---------|
| | | psi | (kPa) | |
| Class 200, DR11 Pipe | 2, 3, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24, 26, 28, 30, 32, 34, 36 in. | 200 | (1375) | a, b, c |
| Class 200, DR11 Pipe | 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630, 710, 800, 900 mm | 200 | (1375) | a, b, c |
| Class 250, DR9 Pipe | 2, 3, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24, 26, 28, 30, 32, 34, 36 in. | 250 | (1720) | a, b, c |
| Class 250, DR9 Pipe | 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630, 710, 800, 900 mm | 250 | (1720) | a, b, c |
| Class335, DR7Pipe | 2, 3, 4, 6, 8, 10, 12,14, 16, 18, 20, 22, 24 in. | 335 | (2305) | a, b, c |
| Class335, DR7Pipe | 50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630 mm | 335 | (2305) | a, b, c |



Member of the FM Global Group